

Files: S600K
S650
ULC G5.2
CCF7

June 15, 2016

STANDARDS BULLETIN 2016-24

Withdrawal of ULC-S650

STANDARD FOR THE INSTALLATION AND PERFORMANCE OF VENTILATION AND FIRE SUPPRESSION SYSTEMS FOR COMMERCIAL AND INSTITUTIONAL COOKING EQUIPMENT

ULC Standards is pleased to announce the withdrawal of ULC-S650, Standard for the Installation and Performance of Ventilation and Fire Suppression Systems for Commercial and Institutional Cooking Equipment. This withdrawal of a ULC Standard was approved by the ULC Standards Committee on Kitchen Exhaust Equipment and Systems, and is published under the date of June 2016.

These ventilators are for use with exhaust systems serving restaurant type cooking equipment such as ranges, broilers, deep fat fryers, grilles, etc.

They are complete units, which may include a fan, motor, enclosing housing, roof penetration and duct connection flange.

They are intended for use in exhaust systems incorporating exhaust hoods.

They are designed to safely remove residual exhaust vapours and air-borne particles from the cooking area and discharge these exhaust products at a minimum height of 1000 mm above roof level

ULC-S650 is currently not referenced in the National Building Code of Canada or other Codes and Regulations.

Should you require additional information, please contact John Wade at (613) 368-4426 or by email at address: John.Wade@ul.com.

Yours, truly



Mahendra (Mike) Prasad
Operations Manager
ULC Standards
Mahendra.Prasad@ul.com



John Wade
Project Manager
ULC Standards
John.Wade@ul.com